

# CERTIFICATE

## of constancy of performance

### 1922 - CPR - 1292

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Smoke and heat control systems. Specification for natural smoke and heat exhaust ventilators:**

- Safe Dome SL PN (EL) - single leaf with pneumatic actuator for main purpose and electrical actuator for daily ventilation, dimensions: from 800x2600mm to 2000x3000mm; base from 300mm to 500mm, polycarbonate thickness from 10 mm to 25 mm;

Clasification: WL 950; SL 750; T (-25); Re 10000; B 300; B-s1,d0

- Safe Dome SL EL - single leaf with electrical actuator for main purpose and daily ventilation, dimensions: from 800x800mm to 1500x2500mm; base from 300mm to 500mm, polycarbonate thickness from 10 mm to 25 mm;

Clasification: WL 1500; SL 750; T (-25); Re 10000; B 300; B-s1,d0

Free aerodynamic area, presented in Annex 1 to 1922-CPR-1292 that is an inseparable part of this certificate placed on the market under the name or trade mark of

**WELKINS FIRE PROTECTION SOLUTIONS SRL**

**8A Fabrica de Zahar St., City of Racari, regional country Dambovita, Romania**  
and produced in the manufacturing plant

**WELKINS FIRE PROTECTION SOLUTIONS SRL**

**8A Fabrica de Zahar St., City of Racari, regional country Dambovita, Romania**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard


**EN 12101-2:2003**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 09.12.2019 and will remain valid until 20.06.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).



Issued:  
Burgas, 18 June 2021  
Ref. No. 01-00



Manager:

*Anna Vasileva*

dipl. eng. Anna Vasileva